



**ORIGINAL**

LORD Corporation  
2000 West Grandview Blvd.  
Erie, PA 16509-1029  
USA  
+1 814 868 0924  
www.lord.com

Mr. David P. Turner, RPM (3HS22)  
Western PA Section  
United States Environmental Protection Agency, Region 3  
1650 Arch Street  
Philadelphia, PA 19103-2029

July 13, 2009

Reference: LORD-Shope RA Monthly Progress Report

Dear Mr. Turner:

LORD is hereby submitting two copies of the monthly progress report for the period of June 1, 2009 through June 30, 2009.

The following work was conducted during this period:

**REMEDIAL ACTION**

**NPDES Report:**

The June report will be submitted under a separate cover.

**Thermal Oxidizer:**

The thermal oxidizer was taken off-line on October 31<sup>st</sup> and resumed operation on May 1<sup>st</sup> as planned. It was taken off-line again on June 1<sup>st</sup> and was back on-line June 24<sup>th</sup> for a planned one month operation.

**Groundwater Treatment:**

The groundwater treatment system was operating normally during this interim.

The groundwater TOC effluent concentration was 2.1 mg/l.

Sincerely,

LORD Corporation

  
George M. Kickel  
Director, Environment, Safety, Health, and Regulatory Compliance

GMK09015/cmf

cc:  ARCADIS G & M, Inc.  
John Morettini, PADEP